



* CONCRETE STRENGTH IS 4,000 PSI @ 28 DAYS
 * STRUCTURE JOINTS TO BE SEALED WITH FLAT BUTYL SEALANT (CONSEAL)



28021 Coker-Vail Road Holden, LA
 Phone (225) 567 - 2700 Fax (225) 567 - 3089

www.gaineyconcrete.com

EFFLUENT LIFT STATION

48" DIAMETER

8/22/05